



# Progress Report

**Client:** Jurys Inn

**Facility:** The Midland Hotel Manchester

**Report Date:** 28/04/2019

**Roof Section:** Main Roof

## Report Data

**Title** Progress Report 25-4-19

Latest site visit carried out by Tom Boon and Daniel Crowley, regional technical manager for the Garland Company on Thursday 25th of April.

Time of Site Visit: 10:00 am

N.o of operatives on Site: 3 roofers

Weather Conditions: 12 degrees - showers

General Comments:

I visited the site to go over the general progress of works with the operatives on site. Work is progressing at a great rate the contractors have now fully stripped the final area of the back mezzanine installed the VCL, base sheet and part of the cap sheet.

I took the time to walk all the completed areas physically pulling at the laps which all display a great bleed out and bond the substrate, all area have been well primed and upstand heights have been achieved

I really happy with all the detailing work in this area, the contractor has taken care to ensure a tidy finish, especially around the dome penetrations.

I will be attending site again later this week to provide further updates



**Photo 1**

Overview of roof section



**Photo 2**

Overview of roof section




**Photo 3**

required bleed out achieved



**Photo 4**

All upstand membranes are well bonded



**Photo 5**

Sole plate has been used



**Photo 6**

Great detailing around this section



**Photo 7**

Base sheet is well bonded in this area